



Load Bank Test Report

Engine Make/ Model: Vortex GM 8.1L
 Engine Spec/ Serial: 8P1L09341
 Unit Make/ Model: G125G1
 Unit Spec/ Serial: OLY00000KNGT00279

Voltage: 208
 Amperage: 347
 Kilowatts: 125
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	59.8	59.9	60.1	60.4	60.7	60.9	61
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	0	205	206	206	205	205	0
PH2	0	205	206	206	205	206	0
PH3	0	206	205	206	206	205	0
Amperage PH1	0	266	265	265	266	266	0
PH2	0	265	266	266	265	266	0
PH3	0	266	265	265	266	265	0
Kilowatts	0	95	95	95	95	95	0
Oil Pressure	0	40	40	40	40	40	0
Coolant Temperature	140	140°F	147°F	147°F	147°F	147°F	147°F
DC Voltage	13	13	13	13	13	13	13
Ambient Temperature	42	42°F	42°F	42°F	42°F	42°F	42°F

Technician Signature Jonathan Mueller

Test Date 2/7/2024



2/7/2024

CSDG #3923

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -25
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: 1 (Battery is missing info tags. 12Vdc System)
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger: 120V, 1.1A, 50/60Hz
- Yes No NA Genset has coolant heater: TPS151GT10-000, 120V, 1500W
- Yes No NA Check engine oil level: Acceptable Level, Oil looks clean
- Yes No NA Engine oil filters last changed date and HRS:
- Yes No NA Inspect exhaust system for cracks / leaks: Good
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: