



Customer: Central States Diesel Generators STK#3924
Address: 2001 S. Prairie Ave.
City/ State/ Zip: Waukesha, WI 53189
Contact: Patrick Paden
Phone: 847.997.8090

R#: 14622
Test Date: 8-4-23

Engine Make/ Model: MITSUBISHI S16R-Y2PTAW2-1
Engine Spec/ Serial: 14859
Unit Make/ Model: KOHLER 2000RE0ZMB
Unit Spec/ Serial: 2272714

Voltage: 277/480
Amperage: 2405
Kilowatts: 2000
Power Factor: 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1181.6	1181.9	1182.1	1182.4	1182.6	1182.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	483	484	483	483	484	484
PH1-PH3	484	484	483	483	483	484
PH2-PH3	484	484	484	483	483	484
Amperage PH1	2352	2350	2351	2352	2350	0
PH2	2354	2355	2356	2352	2354	0
PH3	2347	2350	2348	2349	2346	0
KILOWATTS	1966	1971	1966	1967	1968	0
Oil Pressure	88	82	80	80	80	88
Oil Temperature						
Coolant Temperature	165°F	165°F	165°F	165°F	166°F	162°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	78°F	78°F	78°F	79°F

Technician Signature: _____

Customer Signature: _____



8/4/2023

CSDG # 3924

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: Qty.2 208V/1PH/9000W
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: Not Labeled
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Open Unit
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator: Yes
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: