



Load Bank Test Report

Engine Make/ Model: Ford 6.8L
Engine Spec/ Serial: WSG1068
Unit Make/ Model: Cummins 85
Unit Spec/ Serial: C050755886

Voltage: 208
Amperage: 142
Kilowatts: 49
Power Factor: 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	826.1	826.2	826.5	826.7	827	827.2	827.2
Hertz/Cycles	60.1	60	60	60	60	60	60.1
Voltage PH1	208	208	208	208	208	208	208
PH2	208	208	208	208	208	208	208
PH3	208	208	208	208	208	208	208
Amperage PH1	0	142	142	142	142	142	0
PH2	0	142	142	142	142	142	0
PH3	0	142	142	142	142	142	0
Kilowatts	0	49	49	49	49	49	0
Oil Pressure	73	64	61	60	60	59	66
Coolant Temperature	164	195°F	194°F	194°F	196°F	194°F	192°F
DC Voltage	14.1	14.2	14.2	14.2	14.2	14.2	14.2
Ambient Temperature	15	15°F	15°F	15°F	15°F	15°F	15°F

Technician Signature Jack Standley Jr

Test Date 12/21/2022



12/21/2022

CSDG #3925

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -26F
- Yes No NA Visual inspection of radiator: Clean, no leaks
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: Grp 31, Qty 1
- Yes No NA Battery install date if applicable: 07/01/2020
- Yes No NA Genset has battery charger: No
- Yes No NA Genset has coolant heater: 1500W, 120V
- Yes No NA Check engine oil level: Good, clean
- Yes No NA Engine oil filters last changed date and HRS: No date on filter
- Yes No NA Inspect exhaust system for cracks / leaks: Good
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator: Yes
- Yes No NA Electronic Engine: Yes