



Customer: Central States Diesel Generators STK#3938
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: TBA
 Test Date 8-15-23

Engine Make/ Model: DOOSAN P222FE
 Engine Spec/ Serial: 101853
 Unit Make/ Model: GENERAC SD0600
 Unit Spec/ Serial: 2112609

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	260.4	260.7	260.9	261.2	261.4	261.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	480	480	480	480	480	480
PH1-PH3	481	481	481	480	480	481
PH2-PH3	481	481	481	481	481	481
Amperage PH1	717	718	718	717	717	0
PH2	718	719	718	717	718	0
PH3	717	717	717	718	718	0
KILOWATTS	597	597	596	597	597	0
Oil Pressure	54	53	53	53	53	55
Oil Temperature						
Coolant Temperature	165°F	166°F	165°F	165°F	166°F	166°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.7	27.7	27.7	27.7	27.7	27.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	63°F	63°F	64°F	64°F	64°F	65°F

Technician Signature: _____

Customer Signature: _____



8/15/2023

CSDG # 3938

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (2) NAPA 7266 8D
- Yes No NA Battery install date if applicable: 10/2019
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 3000W/240VAC
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 3-10-22 234 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Tested w/o muffler and rain caps
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator: Yes
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: