



Load Bank Test Report

Engine Make/ Model: Cummins LTA10-G1
Engine Spec/ Serial: 34679477
Unit Make/ Model: 200DFAA
Unit Spec/ Serial: L920493772

Voltage: 208
Amperage: 555A
Kilowatts: 200
Power Factor: 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	732.3	732.3	732.6	732.8	733.1	733.4	733.6
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	210	208	208	208	208	208	210
PH2	210	208	208	208	208	208	210
PH3	210	208	208	208	208	208	210
Amperage PH1	0	555	555	555	555	555	0
PH2	0	555	555	555	555	555	0
PH3	0	555	555	555	555	555	0
Kilowatts	0	200	200	200	200	200	0
Oil Pressure	50	50	45	45	45	45	45
Coolant Temperature	150	175°F	175°F	175°F	175°F	175°F	170°F
DC Voltage	28.1	28.2	28.2	28.2	28.2	28.2	18.1
Ambient Temperature	35	35°F	35°F	35°F	35°F	35°F	35°F

Technician Signature Jack Standley Jr

Test Date 1/11/2023



01/10/2023

CSDG #3957

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -18F
- Yes No NA Visual inspection of radiator: Clean, no leaks.
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: No Batteries
- Yes No NA Battery install date if applicable: NA
- Yes No NA Genset has battery charger: No
- Yes No NA Genset has coolant heater: 2500W
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 06/03/2021 725 Hrs
- Yes No NA Inspect exhaust system for cracks / leaks: Good
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator: Yes
- Yes No NA Electronic Engine: Yes