



Customer: Central States Diesel Generators STK#3971
Address: 2001 S. Prairie Ave.
City/ State/ Zip: Waukesha, WI 53189
Contact: Patrick Paden
Phone: 847.997.8090

R#: 14815
Test Date: 1-8-24

Engine Make/ Model: CUMMINS 6BT5.9-G6
Engine Spec/ Serial: 46337059
Unit Make/ Model: CUMMINS DGDA-5632141
Unit Spec/ Serial: Spec. R S/N-I030547005

Voltage: 120/240 1PH
Amperage: 223
Kilowatts: 53.6
Power Factor: 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	719.3	719.5	719.8	720	720.3	720.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	242	242	242	242	242	242
PH1-N	122	122	122	122	122	122
PH2-N	121	121	121	121	121	121
Amperage PH1	219	220	219	218	219	0
PH2	218	218	219	218	218	0
KILOWATTS	53	53	53	53	53	0
Oil Pressure	68	67	67	67	67	68
Oil Temperature						
Coolant Temperature	168°F	168°F	169°F	169°F	169°F	166°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	30°F	30°F	30°F	30°F	31°F	31°F

Technician Signature: _____

Customer Signature: _____



1/8/2024

CSDG # 3971

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -30F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (1) Kohler GM106699-S Group 31
- Yes No NA Battery install date if applicable: Not Marked
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 120V/1500W Tank Type
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 2/23 718 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: