



Customer: Central States Diesel Generators STK#4057
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 14817
 Test Date 8-28-23

Engine Make/ Model: JOHN DEERE 4045TF150
 Engine Spec/ Serial: PE4045T200534
 Unit Make/ Model: KOHLER 50REOZJB
 Unit Spec/ Serial: Spec. GM21199-GA1 S/N-0733551

Voltage: 120/240 1PH
 Amperage: 229
 Kilowatts: 55
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	299.8	300	300.3	300.5	300.8	300.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	240	240	240	240	240	240
PH1-N	120	121	121	120	120	121
PH2-N	120	120	120	120	121	121
Amperage PH1	230	229	229	230	230	0
PH2	229	229	230	230	230	0
KILOWATTS	55	55	55	55	55	0
Oil Pressure	55	55	55	55	55	58
Oil Temperature						
Coolant Temperature	182°F	182°F	183°F	183°F	183°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	62°F	62°F	63°F	63°F	64°F	64°F

Technician Signature: _____

Customer Signature: _____



8/28/2023

CSDG # 4057

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -35F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger: GM11849 90-132VAC/12VDC
- Yes No NA Genset has coolant heater: 120VAC/1500W Tank Style
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: NOT MARKED
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine:

