



ARC GENERATOR SERVICE, LLC
 1240 Icehouse Ave.
 Sparks, NV 89431 (775) 376-3736

Service Report

Date:	04-25-23	Work Order:	1190	Customer:	Critical Infrastructure Group
Make:	WhisperWatt	Model:	DCA-400SSV	Address:	1280 Ice House Ave.,
Serial Number:	3770380	Hours:	232.7		
KW	400	Volts:	208	HZ:	60
Instructions:	Perform Annual Service and 2 Hr Load Bank				

Service Work Performed

Repair Process	Annual service was performed, Oil and Filters Changed. Generator was test Ran and Load Tested Seperate report was Generated for the Load Testing. No Issues noted during the 2 Hr Load Test.
-----------------------	--

Customer Signature:	TECHNICIAN SIGNATURE: Andy Malone
----------------------------	--