



Customer: Central States Diesel Generators STK#4071  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 15024  
 Test Date 5-17-23

Engine Make/ Model: ISUZU BH-6UZ1X  
 Engine Spec/ Serial: 521100  
 Unit Make/ Model: MULTIQUIP DCA-250SSIU  
 Unit Spec/ Serial: 9000141

Voltage: 277/480  
 Amperage: 265  
 Kilowatts: 220  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	3685	3685.2	3685.5	3685.7	3586	3586.1
Hertz/Cycles	61	61	61	61	61	61
Voltage PH1-PH2	481	481	482	481	481	481
Voltage PH1-PH3	480	481	481	481	480	480
Voltage PH2-PH3	481	482	482	482	481	481
Amperage PH1	264	265	265	264	264	0
PH2	264	263	265	264	264	0
PH3	265	265	265	264	265	0
KILOWATTS	220	220	220	220	220	0
Oil Pressure	26	25	25	25	25	26
Oil Temperature						
Coolant Temperature	190°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	57°F	57°F	57°F	56°F	56°F	56°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

5-17-23

CSDG # 4071

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: Level Good -40F
- Yes  No  NA Visual inspection of radiator: No visible issues or performance issues
- Yes  No  NA Visual inspection of radiator hoses: No visible issues
- Yes  No  NA Check condition of coolant hoses: Good Condition
- Yes  No  NA Check condition of fuel hoses: No visible issues
- Yes  No  NA Check condition of engine belts: Good Condition
- Yes  No  NA Batteries and QTY: (2) 8D RC300 100CCA
- Yes  No  NA Battery install date if applicable: Not Marked
- Yes  No  NA Genset has battery charger: SENS FC24-6-2011U
- Yes  No  NA Genset has coolant heater: 120VAC 1800W Kim Hotstart
- Yes  No  NA Check engine oil level: Oil level is full
- Yes  No  NA Engine oil filters last changed date and HRS: 7-21-22 3204 Hrs.
- Yes  No  NA Inspect exhaust system for cracks / leaks: No issues with exhaust system
- Yes  No  NA Check rain cap for proper operation: Good
- Yes  No  NA Generator end is 12 lead reconnectable: YES
- Yes  No  NA Generator end has PMG permanent magnet generator: YES