



Customer: Central States Diesel Generators STK# 4077
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15087
 Test Date 10-31-24

Engine Make/ Model: PERKINS ND722999
 Engine Spec/ Serial: *U726593F*
 Unit Make/ Model: CATERPILLAR D125P1
 Unit Spec/ Serial: E6456A/001

Voltage: 277/480
 Amperage: 150
 Kilowatts: 125
 Power Factor 1

	5 Min.	15 Min.	15 Min.	15 Min.	15 Min.	5 Min.
Eng Hours	446.6	446.9	447.1	447.4	447.6	447.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	477	477	476	476	477	477
PH1-PH3	476	477	477	476	476	477
PH2-PH3	477	476	477	477	477	477
Amperage PH1	149	150	150	149	150	0
PH2	150	149	149	150	150	0
PH3	149	149	150	150	149	0
KILOWATTS	123	123	124	123	124	0
Oil Pressure	57	56	55	55	55	57
Oil Temperature						
Coolant Temperature	175°F	175°F	175°F	175°F	175°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	62°F	62°F	62°F	61°F	61°F	60°F

Technician Signature: Randall Pool

Customer Signature: _____



10/31/2024

CSDG # 4077

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-35F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: Qty. (1) Caterpillar 115-2422 (12 VDC) (Battery starts unit)
- Yes No NA Battery install date if applicable: 10/08
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 120VAC/1500W
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: NOT LABELED
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Mechanical Engine: