



Customer: Central States Diesel Generators STK#4090
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15252
 Test Date 9-11-23

Engine Make/ Model: CUMMINS DQDAA-5864159
 Engine Spec/ Serial: Spec. B S/N- F070071184
 Unit Make/ Model: CUMMINS QSL9G3
 Unit Spec/ Serial: 46751710

Voltage: 277/480
 Amperage: 301
 Kilowatts: 250
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	423.7	424	424.2	424.5	424.7	424.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	484	484	485	485	485	484
PH2-PH3	481	481	480	480	481	481
PH1-PH3	482	482	483	483	483	482
Amperage PH1	299	299	300	300	298	0
PH2	299	300	300	301	300	0
PH3	297	298	297	297	298	0
KILOWATTS	250	250	250	250	250	0
Oil Pressure	55	54	53	53	53	55
Oil Temperature						
Coolant Temperature	187°F	187°F	186°F	187°F	187°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	57°F	58°F	58°F	58°F	59°F	59°F

Technician Signature: _____

Customer Signature: _____



9/11/2023

CSDG # 4090

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -35F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (2) 12V 4D (4.8VDC)
- Yes No NA Battery install date if applicable: 1-2018
- Yes No NA Genset has battery charger: SENS NRG22-10-RC
- Yes No NA Genset has coolant heater: 120VAC/1500WATT
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 12-1-2021 390.2 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: