



Customer: Central States Diesel Generators STK#4099  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 15253  
 Test Date 7-6-23

Engine Make/ Model: Ford WSG1068  
 Engine Spec/ Serial: E172A-170712-1990571 Spec.6P-680-AA  
 Unit Make/ Model: OLYMPIAN G150LG2  
 Unit Spec/ Serial: OLY00000GXC01973

Voltage: 120/240 1PH  
 Amperage: 625  
 Kilowatts: 150 (Test@100KW)  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	191.8	192	192.3	192.5	192.8	192.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	241	241	241	241	241	241
Voltage PH1-N	120	121	120	120	120	120
Voltage PH2-N	120	120	121	120	120	120
Amperage PH1	416	417	417	416	416	0
PH2	417	416	416	416	416	0
						0
KILOWATTS	100	100	100	100	100	0
Oil Pressure						
Oil Temperature	67°F	67°F	66°F	66°F	66°F	65°F
Coolant Temperature	193°F	193°F	194°F	194°F	194°F	188°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	12.5	12.5	12.5	12.5	12.5	12.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	74°F	74°F	74°F	74°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

7-6-23

CSDG #4099

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: Level Good -40F
- Yes  No  NA Visual inspection of radiator: No visible issues or performance issues
- Yes  No  NA Visual inspection of radiator hoses: No visible issues
- Yes  No  NA Check condition of coolant hoses: Good Condition
- Yes  No  NA Check condition of fuel hoses: No visible issues
- Yes  No  NA Check condition of engine belts: Good Condition
- Yes  No  NA Batteries and QTY: (Qty. 1) NAPA 7237
- Yes  No  NA Battery install date if applicable: 4/22
- Yes  No  NA Genset has battery charger: OLYMPIAN (in control panel)
- Yes  No  NA Genset has coolant heater: 120VAC/1500W
- Yes  No  NA Check engine oil level: Oil level is full
- Yes  No  NA Engine oil filters last changed date and HRS: Not Marked
- Yes  No  NA Inspect exhaust system for cracks / leaks: No issues with exhaust system
- Yes  No  NA Check rain cap for proper operation: OPEN UNIT
- Yes  No  NA Generator end is 12 lead reconnectable: YES
- Yes  No  NA Generator end has PMG permanent magnet generator: YES