



Customer: Central States Diesel Generators STK#4102
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15491
 Test Date 8-18-23

Engine Make/ Model: CUMMINS VTA28G5
 Engine Spec/ Serial: 25264052
 Unit Make/ Model: CUMMINS DFGB-4481997
 Unit Spec/ Serial: Spec. G S/N-G000131889

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	365.9	366.2	366.4	366.7	366.9	367
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	481	481	481	481	481	481
PH1-PH3	480	480	480	480	480	480
PH2-PH3	481	481	481	481	481	481
Amperage PH1	720	702	721	720	721	0
PH2	721	721	721	721	720	0
PH3	720	720	720	721	720	0
KILOWATTS	600	600	600	600	600	0
Oil Pressure	68	65	64	63	63	65
Oil Temperature						
Coolant Temperature	190°F	190°F	191°F	191°F	191°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	72°F	72°F	73°F	73°F

Technician Signature: _____

Customer Signature: _____