



Customer: Central States Diesel Generators STK#4107
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15495
 Test Date 9-15-23

Engine Make/ Model: JOHN DEERE 6068HFG85
 Engine Spec/ Serial: PE6068L975961
 Unit Make/ Model: KOHLER 200REOZJF
 Unit Spec/ Serial: Spec. GM81290-GA5 S/N-SGM32F3KM

Voltage: 277/480
 Amperage: 241
 Kilowatts: 200
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	163.6	163.8	164.1	164.3	164.6	164.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	478	478	479	479	478	478
PH2-PH3	479	479	478	478	478	479
PH1-PH3	478	478	478	479	479	478
Amperage PH1	242	242	243	243	242	0
PH2	243	243	244	243	242	0
PH3	243	243	242	242	243	0
KILOWATTS	200	200	200	200	200	0
Oil Pressure	55	54	53	52	52	54
Oil Temperature						
Coolant Temperature	186°F	186°F	187°F	187°F	187°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	74°F	74°F	74°F	73°F	73°F	73°F

Technician Signature: _____

Customer Signature: _____



9/15/2023

CSDG # 4107

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -35F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 120V/1800W
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 10-12-22 150 HRS.
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: