



Customer: Central States Diesel Generators #4115
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip: Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15383
 Test Date 2023.06.29

Engine Make/ Model: CUMMINS 6CTAA8.3G1
 Engine Spec/ Serial: 45821682
 Unit Make/ Model: CUMMINS/ ONAN DGFC-3367977
 Unit Spec/ Serial: C9908766010

Voltage: 480
 Amperage: 240
 Kilowatts: 200
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	271.8	271.9	272.2	272.5	272.7	272.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	236	236	236	236	236	0
PH2	239	239	239	239	239	0
PH3	238	238	238	238	238	0
Kilowatts	197	197	197	197	197	0
Oil Pressure	82	63	61	60	60	73
Coolant Temperature	179°F	180°F	183°F	183°F	184°F	175°F
DC Voltage	14	14	14	14	14	14
Ambient Temperature	69°F	69°F	69°F	69°F	69°F	69°F

Technician Signature: Juan Cardenas

Customer Signature: _____