



Customer: Central States Diesel Generators STK#4127
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15497
 Test Date 10-5-23

Engine Make/ Model: JOHN DEERE 6081TF001
 Engine Spec/ Serial: RG6081T151507
 Unit Make/ Model: KOHLER 135ROZJ
 Unit Spec/ Serial: Spec.PA-189724 S/N 0730488

Voltage: 277/480
 Amperage: 162
 Kilowatts: 135
 Power Factor 1

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 368.5 | 368.8 | 369 | 369.3 | 369.5 | 369.6 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1-PH2 | 478 | 478 | 478 | 479 | 478 | 478 |
| PH2-PH3 | 477 | 477 | 478 | 478 | 477 | 477 |
| PH1-PH3 | 479 | 479 | 479 | 478 | 479 | 479 |
| Amperage PH1 | 163 | 162 | 163 | 163 | 163 | 0 |
| PH2 | 164 | 163 | 163 | 163 | 163 | 0 |
| PH3 | 162 | 162 | 161 | 161 | 162 | 0 |
| KILOWATTS | 135 | 135 | 135 | 135 | 135 | 0 |
| Oil Pressure | 43 | 41 | 40 | 40 | 40 | 42 |
| Oil Temperature | | | | | | |
| Coolant Temperature | 190°F | 190°F | 190°F | 190°F | 190°F | 175°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 14 | 14 | 14 | 14 | 14 | 14 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 65°F | 65°F | 65°F | 65°F | 66°F | 66°F |

Technician Signature: _____

Customer Signature: _____



10/5/2023

CSDG # 4127

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -35F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (1) 31-5 12V
- Yes No NA Battery install date if applicable: 8/16
- Yes No NA Genset has battery charger: Kohler D-292863 120/240VAC/13VDC/10A
- Yes No NA Genset has coolant heater: 120V/1500W Tank Type
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 1-15-21 344.2Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: