



Customer: Central States Diesel Generators STK#4138
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15596
 Test Date 9-12-23

Engine Make/ Model: CUMMINS DGEA-4478169
 Engine Spec/ Serial: Spec. L S/N-C000078477
 Unit Make/ Model: CUMMINS 6CT8.3G2
 Unit Spec/ Serial: 45908038

Voltage: 120/208
 Amperage: 347
 Kilowatts: 125
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	182.5	182.7	183	183.2	183.5	183.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	210	210	210	209	209	210
PH2-PH3	209	209	209	209	210	209
PH1-PH3	210	211	211	210	210	210
Amperage PH1	346	346	345	347	345	0
PH2	344	345	345	345	344	0
PH3	346	347	347	346	346	0
KILOWATTS	125	125	125	125	125	0
Oil Pressure	60	60	60	60	60	65
Oil Temperature						
Coolant Temperature	182°F	182°F	181°F	181°F	182°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	55°F	55°F	55°F	56°F	56°F	56°F

Technician Signature: _____

Customer Signature: _____



9/12/2023

CSDG # 4138

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -30F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 120VAC/1500WATT
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 5-18-2022 172.4 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: