



Customer: Central States Diesel Generators STK#4144  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 15601  
 Test Date 9-12-23

Engine Make/ Model: DETROIT DIESEL 6063Tk35R  
 Engine Spec/ Serial: 06R0772679  
 Unit Make/ Model: BALDOR HCI444F  
 Unit Spec/ Serial: 06R0772679

Voltage: 277/480  
 Amperage: 421  
 Kilowatts: 350  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	177.8	178	178.3	178.5	178.8	178.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	478	478	477	477	478	478
PH2-PH3	478	477	477	477	478	478
PH1-PH3	479	479	478	478	479	479
Amperage PH1	422	422	423	421	422	0
PH2	421	422	422	421	421	0
PH3	423	422	423	422	421	0
KILOWATTS	350	350	350	350	350	0
Oil Pressure	65	63	62	62	62	64
Oil Temperature						
Coolant Temperature	195°F	196°F	196°F	196°F	195°F	183°F
Man Vac./Press. L/B			j			
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	65°F	65°F	65°F	65°F	66°F	66°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_



**9/12/2023**

**CSDG # 4144**

## Generator Check list

### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: -40F
- Yes  No  NA Visual inspection of radiator: Good
- Yes  No  NA Visual inspection of radiator hoses: Good
- Yes  No  NA Check condition of coolant hoses: Good
- Yes  No  NA Check condition of fuel hoses: Good
- Yes  No  NA Check condition of engine belts: Good
- Yes  No  NA Batteries and QTY:
- Yes  No  NA Battery install date if applicable:
- Yes  No  NA Genset has battery charger:
- Yes  No  NA Genset has coolant heater: 120VAC/2500WATT
- Yes  No  NA Check engine oil level: Good
- Yes  No  NA Engine oil filters last changed date and HRS: 9-1-2022
- Yes  No  NA Inspect exhaust system for cracks / leaks: None
- Yes  No  NA Check rain cap for proper operation: Open Unit
- Yes  No  NA Generator end is 12 lead reconnectable: Yes
- Yes  No  NA Generator end has PMG permanent magnet generator:
- Yes  No  NA Electronic Engine:
- Yes  No  NA Mechanical Engine: