



Customer: Central States Diesel Generators STK#4146
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15839
 Test Date 1-18-24

Engine Make/ Model: GM 4.3L
 Engine Spec/ Serial: 16808
 Unit Make/ Model: BALDOR IGLC35-2GU
 Unit Spec/ Serial: Spec.10.95035-G7 S/N-P0310300002

Voltage: 120/208
 Amperage: 97
 Kilowatts: 35
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	119.9	120.1	120.4	120.6	120.9	121
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	207	206	206	206	207	207
PH1-PH3	207	206	206	207	206	207
PH2-PH3	206	206	206	207	206	206
Amperage PH1	97	97	96	96	97	0
PH2	96	96	97	97	97	0
PH3	97	96	96	97	97	0
KILOWATTS	34	34	34	34	34	0
Oil Pressure	50	48	48	48	48	50
Oil Temperature						
Coolant Temperature	185°F	188°F	188°F	188°F	189°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	9°F	9°F	9°F	9°F	10°F	10°F

Technician Signature: _____

Customer Signature: _____