



Customer: Central States Diesel Generators STK#4172
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15815
 Test Date 9-20-23

Engine Make/ Model: CATERPILLAR C13
 Engine Spec/ Serial: *K3B00872*
 Unit Make/ Model: CATERPILLAR QX350-C13
 Unit Spec/ Serial: CATXQ350TX3M00459

Voltage: 277/480
 Amperage: 421
 Kilowatts: 350
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	9429.3	9429.5	9429.8	9430	9430.3	9430.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	483	483	482	482	482	483
PH2-PH3	482	482	482	482	483	482
PH1-PH3	483	482	482	483	483	483
Amperage PH1	420	419	419	420	421	0
PH2	419	420	420	419	419	0
PH3	418	419	418	418	419	0
KILOWATTS	350	350	350	350	350	0
Oil Pressure	56	55	54	54	54	56
Oil Temperature						
Coolant Temperature	181°F	181°F	182°F	182°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.1	27.1	27.1	27.1	27.1	27.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	77°F	76°F	76°F	76°F

Technician Signature: _____

Customer Signature: _____