



Customer: Central States Diesel Generators STK#4175
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 15824
 Test Date 10-4-23

Engine Make/ Model: GM 8.1L
 Engine Spec/ Serial: 8.1L-07960
 Unit Make/ Model: KOHLER 125RGZ
 Unit Spec/ Serial: Spec. GM25339-GA1 S/N 0775842

Voltage: 120/208
 Amperage: 361
 Kilowatts: 130 (Test@66KW LP)
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	308	308.2	308.5	308.7	309	309.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	209	209	209	208	208	209
PH2-PH3	208	208	208	208	208	208
PH1-PH3	209	209	210	210	209	209
Amperage PH1	181	182	182	181	182	0
PH2	182	182	183	183	182	0
PH3	182	183	183	182	182	0
KILOWATTS	66	66	66	66	66	0
Oil Pressure	54	52	50	50	50	52
Oil Temperature						
Coolant Temperature	175°F	175°F	175°F	175°F	175°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	73°F	73°F	74°F	74°F

Technician Signature: _____

Customer Signature: _____



10/4/2023

CSDG # 4175

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -35F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger: KOHLER GM28341 115VAC/12VDC/6A
- Yes No NA Genset has coolant heater: 120V/1500W
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: Not Marked
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: PSI EEC
- Yes No NA Mechanical Engine: