



Customer: Central States Diesel Generators STK#4192  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 15912  
 Test Date 10-5-23

Engine Make/ Model: CUMMINS NTA-855-G3  
 Engine Spec/ Serial: 30364027  
 Unit Make/ Model: CUMMINS DFCC-3387631  
 Unit Spec/ Serial: Spec.T S/N A000055537

Voltage: 277/480  
 Amperage: 421  
 Kilowatts: 350  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	646.8	647	647.3	647.5	647.8	647.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	482	483	483	483	482	482
PH2-PH3	481	481	482	482	481	481
PH1-PH3	480	480	481	480	480	480
Amperage PH1	420	420	419	419	420	0
PH2	419	419	418	419	419	0
PH3	419	418	418	418	419	0
KILOWATTS	350	350	350	350	350	0
Oil Pressure	52	50	48	48	48	51
Oil Temperature						
Coolant Temperature	185°F	185°F	186°F	186°F	186°F	181°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	55°F	55°F	56°F	56°F	56°F	57°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_



**10/4/2023**

**CSDG # 4192**

### **Generator Check list**

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: -30F
- Yes  No  NA Visual inspection of radiator: Good
- Yes  No  NA Visual inspection of radiator hoses: Good
- Yes  No  NA Check condition of coolant hoses: Good
- Yes  No  NA Check condition of fuel hoses: Good
- Yes  No  NA Check condition of engine belts: Good
- Yes  No  NA Batteries and QTY: (2) PF-8D-7
- Yes  No  NA Battery install date if applicable: 1/2023
- Yes  No  NA Genset has battery charger: LaMarche A46 115VAC/24VDC
- Yes  No  NA Genset has coolant heater: 240/480V/6420W/1PH
- Yes  No  NA Check engine oil level: Good
- Yes  No  NA Engine oil filters last changed date and HRS: 5-17-22 285.2Hrs.
- Yes  No  NA Inspect exhaust system for cracks / leaks: None
- Yes  No  NA Check rain cap for proper operation: Good
- Yes  No  NA Generator end is 12 lead reconnectable: Yes
- Yes  No  NA Generator end has PMG permanent magnet generator:
- Yes  No  NA Electronic Engine:
- Yes  No  NA Mechanical Engine: