



LOAD BANK TEST REPORT

Account Name:

Equipment Location: (Physical Address)

Work Order Number:

Engine	Generator
KOHLER	
600REOZVB	5M4030BF
SGM32CGTS	MT-0016795-1214

PASS / FAIL
PASS

Engine Fluids:

Engine Fluids:	
Oil Level	FULL
Coolant Level	FULL
Beg. Fuel Level	
End Fuel Level	

<u>Service Technician</u>	<u>Test Date</u>
Gus	01/30/2024
<u>Customer Witness</u>	

Load Bank

Make: AVTRON
 Model: 700kW
 Serial Number:

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	3:41pm	138.7	479	59.8	0	0	0	0	75	150	59
2	3:56pm	138.9	478	59.9	147.2	179	179	179	70	181	59
3	4:40pm	139.5	480	59.9	457.2	555	555	555	62	179	58
4	5:00pm	139.8	478	59.8	455.8	548	555	544	62	183	58
5	5:15pm	140.1	481	59.9	602	725	729	732	59	185	57
6											
7											
8											
9											
10											
11											
12											
13											

SIGNATURE: _____

DATE: _____