



Critical Power Services LLC
 16824 Hickory Heights Dr
 Maribel WI 54227
 (920) 370-8909
 criticalpowerservicesllc.com

Load Bank Test Report

Engine Make/ Model: CUMMINS / QSK60-G19
 Engine Spec/ Serial: 33240138
 Unit Make/ Model: CUMMINS / DQKAN*2480467
 Unit Spec/ Serial: D / J250501010

Voltage: 277/480
 Amperage: 3006
 Kilowatts: 2500
 Power Factor 1

TIME	8:00	8:15	8:30	8:45	9:00	9:15	9:30	9:45	10:00	10:15	10:20
	WARMUP	START	15 MIN	30 MIN	45 MIN	60 MIN	75 MIN	90 MIN	105 MIN	120 MIN	COOLDOWN
Eng Hours	4.4	4.6	4.9	5.2	5.4	5.6	5.9	6.2	6.4	6.6	6.7
Hertz/Cycles	60	60	60	60	60	60	60	60	60	60	60
Voltage PH1	480	481	481	480	481	480	480	481	481	481	481
PH2	480	480	480	480	480	480	481	480	480	480	480
PH3	480	379	480	480	480	480	480	480	480	480	480
Amperage PH1	0	3044	3054	3055	3056	3054	3056	3057	3058	3057	0
PH2	0	3173	3143	3144	3145	3142	3144	3145	3147	3145	0
PH3	0	3071	3054	3054	3055	3052	3053	3054	3056	3054	0
Kilowatts	0	2492	2483	2482	2483	2482	2483	2485	2485	2484	0
Oil Pressure	105	72	71	69	69	69	69	70	68	69	76
Coolant Temperature	95	181°F	181°F	181°F	181°F	181°F	181°F	183°F	183°F	183°F	176°F
DC Voltage	25.1	26.3	26.8	27.1	27.3	27.4	27.5	27.6	27.7	27.6	27.7
Ambient Temperature	50	50°F	51°F	51°F	51°F	51°F	51°F	51°F	51°F	51°F	51°F

Technician Signature DYLAN SCHMIDT

Test Date 5/22/2026