



Load Bank Test Report

Engine Make/ Model: John Deere 6068TF250
Engine Spec/ Serial: T06068T844294
Unit Make/ Model: Kohler 100REOZJ
Unit Spec/ Serial: 663627

Voltage: 480
Amperage: 126.3
Kilowatts: 105
Power Factor: 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	637.9	638	638.2	638.5	638.7	639	639.1
Hertz/Cycles	60	59.1	59.1	59.1	59.1	59.1	60
Voltage PH1	480	478	478	478	478	478	480
PH2	480	478	478	478	478	478	480
PH3	480	478	478	478	478	478	480
Amperage PH1	0	120	120	120	120	120	0
PH2	0	122	122	122	122	122	0
PH3	0	122	122	122	122	122	0
Kilowatts	0	101	101	101	101	101	0
Oil Pressure	60	50	45	45	45	45	50
Coolant Temperature	100	180°F	190°F	190°F	190°F	190°F	180°F
DC Voltage	14	14	14	14	14	14	14
Ambient Temperature	74	74°F	74°F	74°F	74°F	74°F	74°F

Technician Signature Jonathan Mueller

Test Date 7/17/2024



7/17/24

CSDG #4364

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -25
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger: Guest 26304, 115V, 1A
- Yes No NA Genset has coolant heater: 84918-A, 1000W, 120V
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 6/16/23, 631.7HRS
- Yes No NA Inspect exhaust system for cracks / leaks: Good
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator: Kohler Photo Eye
- Yes No NA Mechanical Engine: