



## Load Bank Test Report

**Engine Make/ Model:** 16V2000G45-TB  
**Engine Spec/ Serial:** 5362010207  
**Unit Make/ Model:** 900RE0ZDD  
**Unit Spec/ Serial:** GM62260-GA9/3022888

**Voltage:** 277/480  
**Amperage:** 1353  
**Kilowatts:** 900  
**Power Factor:** 0.8

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
<b>Eng Hours</b>	<b>434</b>	434.1	434.2	434.5	434.7	435	425.1
<b>Hertz/Cycles</b>	<b>60</b>	60	60	60	60	60	60
<b>Voltage PH1</b>	<b>486</b>	487	486	487	488	486	486
<b>PH2</b>	<b>486</b>	485	486	487	486	487	489
<b>PH3</b>	<b>486</b>	488	486	487	485	486	488
<b>Amperage PH1</b>	<b>1110</b>	1110	1110	1109	1110	1109	1110
<b>PH2</b>	<b>1024</b>	1024	1025	1024	1024	1024	1024
<b>PH3</b>	<b>1074</b>	1074	1074	1074	1074	1074	1074
<b>Kilowatts</b>	<b>899</b>	900	899	899	899	899	899
<b>Oil Pressure</b>	<b>121</b>	109	100	104	103	100	104
<b>Coolant Temperature</b>	<b>121</b>	152°F	163°F	159°F	159°F	159°F	159°F
<b>DC Voltage</b>	<b>27.6</b>	27.6	27.6	27.6	27.6	27.6	27.6
<b>Ambient Temperature</b>	<b>33</b>	33°F	33°F	33°F	33°F	33°F	33°F

Technician Signature Jonathan Mueller

Test Date 1/25/2024