



Customer: Central States Diesel Generators STK#4367
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 16242
 Test Date 1-25-24

Engine Make/ Model: FORD WSG1068
 Engine Spec/ Serial: 3005107698
 Unit Make/ Model: GENERAC SG0100
 Unit Spec/ Serial: 3005107698

Voltage: 120/240 1PH
 Amperage: 417
 Kilowatts: 100
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	0.9	1.1	1.4	1.6	1.9	2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	241	241	240	241	240	241
PH2-N	120	120	120	120	120	120
PH1-N	120	121	120	120	120	120
Amperage PH1	406	407	406	406	407	0
PH2	408	407	407	407	407	0
KILOWATTS	98	98	97	98	97	0
Oil Pressure	60	58	57	57	57	59
Oil Temperature						
Coolant Temperature	192°F	193°F	193°F	192°F	192°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13	13	13	13	13	13
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	35°F	35°F	35°F	35°F	34°F	34°F

Technician Signature: _____ Customer Signature: _____