



Load Bank Test Report

Engine Make/ Model: WSG1068
 Engine Spec/ Serial: 04PS36812
 Unit Make/ Model: GGHH-5703609
 Unit Spec/ Serial: B050743885

Voltage: 120/240
 Amperage: 240
 Kilowatts: 100
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	361	361	361.2	361.5	361.7	362	362.1
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	240	239	239	239	239	239	240
PH2	240	239	239	239	239	239	240
PH3	240	239	239	239	239	239	240
Amperage PH1	0	182	182	182	182	182	0
PH2	0	183	183	182	182	183	0
PH3	0	182	182	182	183	182	0
Kilowatts	0	75	75	75	75	75	0
Oil Pressure	88	66	66	66	65	65	73
Coolant Temperature	68	198°F	198°F	199°F	199°F	199°F	191°F
DC Voltage	14	14	14	14	14	14	14
Ambient Temperature	49	50°F	51°F	51°F	52°F	52°F	52°F

Technician Signature Jonathan Mueller

Test Date 4/16/2024



4/16/24

CSDG #4383

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -25
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: 1, SLI31AGMDPM
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 0333-0588-01, 1000W, 120V
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 8/2/23, 360hrs
- Yes No NA Inspect exhaust system for cracks / leaks: Good
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Mechanical Engine: