



Customer: Central States Diesel Generators STK#4399  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 16419  
 Test Date 2-28-24

Engine Make/ Model: MTU 12V2000G85  
 Engine Spec/ Serial: 5352011565  
 Unit Make/ Model: KOHLER 800REOZDE  
 Unit Spec/ Serial: Spec. GM88015-C1J S/N SGM328GC9

Voltage: 277/480  
 Amperage: 902  
 Kilowatts: 750  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1.4	1.6	1.9	2.1	2.4	2.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	480	480	482	482	481	481
PH1-PH3	480	482	479	482	480	480
PH2-PH3	480	480	482	479	480	480
Amperage PH1	900	901	901	900	900	0
PH2	898	898	899	900	900	0
PH3	899	900	900	901	901	0
KILOWATTS	750	750	750	750	750	0
Oil Pressure	149	144	132	130	130	134
Oil Temperature						
Coolant Temperature	157°F	160°F	161°F	161°F	162°F	158°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.3	27.3	27.3	27.3	27.3	27.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	23°F	23°F	23°F	22°F	22°F	22°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_



**03/04/2024**

**CSDG # 4399**

### **Generator Check list**

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: -45
- Yes  No  NA Visual inspection of radiator: Good
- Yes  No  NA Visual inspection of radiator hoses: Good
- Yes  No  NA Check condition of coolant hoses: Good
- Yes  No  NA Check condition of fuel hoses: Good
- Yes  No  NA Check condition of engine belts: Good
- Yes  No  NA Batteries and QTY:
- Yes  No  NA Battery install date if applicable:
- Yes  No  NA Genset has battery charger:
- Yes  No  NA Genset has coolant heater: HotStart Part# 59896732
- Yes  No  NA Check engine oil level: Good
- Yes  No  NA Engine oil filters last changed date and HRS: 02/27/24, 1hr
- Yes  No  NA Inspect exhaust system for cracks / leaks:
- Yes  No  NA Check rain cap for proper operation:
- Yes  No  NA Generator end is 12 lead reconnectable:
- Yes  No  NA Generator end has PMG permanent magnet generator: Kohler Photo Eye
- Yes  No  NA Electronic Engine: