



Customer: Central States Diesel Generators STK# 4403  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 16421  
 Test Date 3-15-24

Engine Make/ Model: GENERAC SC13GT525D  
 Engine Spec/ Serial: G9145002544  
 Unit Make/ Model: GENERAC MGG200G  
 Unit Spec/ Serial: 1410927

Voltage: 277/480  
 Amperage: 181  
 Kilowatts: 150 Test@75KW LP  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1.3	1.5	1.8	2	2.3	2.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	476	477	476	476	477	476
PH1-PH3	485	484	484	485	485	485
PH2-PH3	479	480	479	479	480	479
Amperage PH1	90	90	90	91	91	0
PH2	88	89	88	89	89	0
PH3	91	90	90	90	91	0
KILOWATTS	75	75	75	75	75	0
Oil Pressure	83	82	82	82	82	84
Oil Temperature						
Coolant Temperature	173°F	173°F	174°F	174°F	173°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	45°F	45°F	45°F	45°F	46°F	46°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_



**03/15/2024**

**CSDG #4403**

### **Generator Check list**

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: -25
- Yes  No  NA Visual inspection of radiator: Good
- Yes  No  NA Visual inspection of radiator hoses: Good
- Yes  No  NA Check condition of coolant hoses: Good
- Yes  No  NA Check condition of fuel hoses: Good
- Yes  No  NA Check condition of engine belts: Good
- Yes  No  NA Batteries and QTY: 2 (8D)
- Yes  No  NA Battery install date if applicable: 3/15/24
- Yes  No  NA Genset has battery charger: 10A, 120V
- Yes  No  NA Genset has coolant heater: 084918N, 2000w, 240v
- Yes  No  NA Check engine oil level: Good
- Yes  No  NA Engine oil filters last changed date and HRS: 3/15/24, 1hr
- Yes  No  NA Inspect exhaust system for cracks / leaks: Good
- Yes  No  NA Check rain cap for proper operation: Good
- Yes  No  NA Generator end is 12 lead reconnectable:
- Yes  No  NA Generator end has PMG permanent magnet generator:
- Yes  No  NA Mechanical Engine: