



Customer: Central States Diesel Generators STK#4408
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 16429
 Test Date 2-15-24

Engine Make/ Model: JOHN DEERE 6068HF485
 Engine Spec/ Serial: PE6068L182249
 Unit Make/ Model: MTU DS00200D6SRAK0574
 Unit Spec/ Serial: 337483-1-1-0911

Voltage: 277/480
 Amperage: 241
 Kilowatts: 200
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	148.3	148.5	148.8	149	149.3	149.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	481	481	480	480	480	481
PH1-PH3	480	480	479	479	480	480
PH2-PH3	481	481	482	481	482	481
Amperage PH1	240	241	241	241	240	0
PH2	241	242	242	241	241	0
PH3	241	242	242	241	241	0
KILOWATTS	200	200	200	200	200	0
Oil Pressure	64	61	58	54	54	57
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	181°F	181°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.2	14.2	14.2	14.2	14.2	14.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	32°F	32°F	32°F	31°F	31°F	31°F

Technician Signature: _____

Customer Signature: _____



2/15/2024

CSDG # 4408

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (1) NAPA 7237 Group 31
- Yes No NA Battery install date if applicable: 12/22
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 2500W Tank Type
- Yes No NA Check engine oil level: New 2-15-24
- Yes No NA Engine oil filters last changed date and HRS: 2/15/24 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: Good
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: