



Customer: CENTRAL STATES DIESEL GENERATORS
 Address: _____
 City/ State/ Zip: _____
 Contact: _____
 Phone: _____

R#: 16553
 Test Date: 3/28/2024
 unit #4442

Engine Make/ Model: CUMMINS. LTA-10H1
 Engine Spec/ Serial: 34985025
 Unit Make/ Model: CUMMINS. DFAC
 Unit Spec/ Serial: E95057828

Voltage: 480
 Amperage: 376
 Kilowatts: 250
 Power Factor: 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	649.4	649.6	649.9	650.2	650.4							650.5
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	483	483	483	480	480							483
Amperage PH1	320	320	320	320	320							
PH2	283	283	283	283	283							
PH3	322	322	322	322	322							
Kilowatts	257	257	257	256	256	0	0	0	0	0	0	0
Oil Pressure	41	38	38	38	38							38
Oil Temperature	85°F	203°F	203°F	203°F	203°F							189°F
Coolant Temperature	180°F	18°F	180°F	180°F	180°F							177°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	27.5	27.5	27.5	27.5	27.5							27.5
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	32°F	32°F	32°F	32°F	32°F							32°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____