



Customer: Central States Diesel Generators STK# 4451  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 16666  
 Test Date 5-1-24

Engine Make/ Model: DETROIT DIESEL 60 Series  
 Engine Spec/ Serial: 06R0551068  
 Unit Make/ Model: KOHLER 230RZD  
 Unit Spec/ Serial: Spec. PA-194259 S/N 0654409

Voltage: 277/480  
 Amperage: 283  
 Kilowatts: 235 (test@100) LP  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	774.7	774.9	775.2	775.4	775.7	775.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	481	481	481	481	481	482
PH1-PH3	482	482	482	481	481	482
PH2-PH3	481	481	481	481	481	481
Amperage PH1	123	122	122	122	123	0
PH2	121	122	122	122	123	0
PH3	122	122	123	123	122	0
KILOWATTS	102	103	103	102	102	0
Oil Pressure	64	63	63	63	63	65
Oil Temperature						
Coolant Temperature	182°F	183°F	183°F	183°F	183°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	68°F	68°F	68°F	68°F	69°F	69°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_



**5/1/2024**

**CSDG # 4451**

### **Generator Check list**

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: (-40F)
- Yes  No  NA Visual inspection of radiator: Good
- Yes  No  NA Visual inspection of radiator hoses: Good
- Yes  No  NA Check condition of coolant hoses: Good
- Yes  No  NA Check condition of fuel hoses: Good
- Yes  No  NA Check condition of engine belts: Good
- Yes  No  NA Batteries and QTY:
- Yes  No  NA Battery install date if applicable:
- Yes  No  NA Genset has battery charger: Voltmaster 60-20A
- Yes  No  NA Genset has coolant heater: 240V/2500W
- Yes  No  NA Check engine oil level:
- Yes  No  NA Engine oil filters last changed date and HRS: Not Labeled
- Yes  No  NA Inspect exhaust system for cracks / leaks:
- Yes  No  NA Check rain cap for proper operation: Open Skid Unit
- Yes  No  NA Generator end is 12 lead reconnectable:
- Yes  No  NA Generator end has PMG permanent magnet generator:
- Yes  No  NA Electronic Engine: