



GENERAC



Customer: CENTRAL STATES DIESEL GENERATORS
 Address: 2001 S. PRAIRIE AVE.
 City/ State/ Zip: WAUKESHA, WI. 53189
 Contact: PATRICK PADEN
 Phone: 1-262-955-7655

R#: 16773
 Test Date 6/11/2024

Engine Make/ Model: JOHN DEERE / 6081AF001
 Engine Spec/ Serial: RG6081A158742
 Unit Make/ Model: KOHLER /180ROZJ
 Unit Spec/ Serial: PA-189973-FAA

Voltage: 480
 Amperage: 216 @ 1.0 p.f.
 Kilowatts: 180
 Power Factor: Rated at .8 Tested at 1

	5 MINUTES	15 MINUTES	30 MINUTES	45 MINUTES	1 HOUR	COOL DOWN
Eng Hours	267.7	268	268.3	268.6	268.8	268.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	480	480	480	480	482
PH2	482	480	480	480	480	482
PH3	482	480	480	480	480	482
Amperage PH1	132	174	217	217	217	0
PH2	131	175	216	216	216	0
PH3	131	176	216	216	216	0
Kilowatts	110	145	180	180	180	0
Oil Pressure	40	35	35	35	35	38
Oil Temperature	75°F	137°F	208°F	208°F	208°F	196°F
Coolant Temperature	150°F	179°F	180°F	180°F	180°F	175°F
Man Vac./Press. L/B	N/A	N/A	N/A	N/A	N/A	N/A
Man Vac./Press. R/B	N/A	N/A	N/A	N/A	N/A	N/A
L/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
R/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
Exhaust Temperature	350°F	452°F	491°F	491°F	491°F	491°F
DC Voltage	14.4 VDC	14.4 VDC	14.4 VDC	14.4 VDC	14.4 VDC	14.4 VDC
Natural Gas Pressure	N/A	N/A	N/A	N/A	N/A	N/A
Diesel Fuel Level	10%	10%	10%	10%	10%	10%
Room Temperature	OUTDOOR	OUTDOOR	OUTDOOR	OUTDOOR	OUTDOOR	OUTDOOR
Ambient Temperature	76°F	76°F	76°F	76°F	76°F	76°F

Cable Length: 15' Cable/ Leg: 3 EA / 1 PER Connection Point: UNIT MOUNTED BREAKER

Technician Signature: CHRISTOPHER A CHICO

Customer Signature: _____