



Customer: Central States Diesel Generators STK#4467
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 1019
 Test Date 4-25-24

Engine Make/ Model: CUMMINS QST30-G5
 Engine Spec/ Serial: 37226474
 Unit Make/ Model: CUMMINS DQFAB-5780851
 Unit Spec/ Serial: Spec. A S/N- A070013150

Voltage: 277/480
 Amperage: 962
 Kilowatts: 800
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	292.6	292.8	293.1	293.3	293.6	293.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	489	489	489	488	489	489
PH1-PH3	489	489	489	490	489	489
PH2-PH3	481	481	480	481	480	480
Amperage PH1	989	988	989	989	988	0
PH2	988	988	989	989	988	0
PH3	987	988	988	988	988	0
KILOWATTS	835	835	835	835	835	0
Oil Pressure	53	53	52	52	52	54
Oil Temperature						
Coolant Temperature	175°F	177°F	177°F	177°F	177°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.7	26.7	26.7	26.7	26.7	26.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	55°F	55°F	54°F	54°F	54°F	53°F

Technician Signature Randy Pool Customer Signature: _____



4/25/2024

CSDG # 4467

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-40F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (2) AGM8D (0 VDC)
- Yes No NA Battery install date if applicable: 1997
- Yes No NA Genset has battery charger: SENS NRG22-10-RC
- Yes No NA Genset has coolant heater: Qty. (2) 6420W, 240/480V 1PH Tank Type
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 8-28-19, 240.5 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Mechanical Engine: