



Customer: Central States Diesel Generators STK#4475
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 17074
 Test Date 6/13/2024

Engine Make/ Model: CATERPILLAR C17
 Engine Spec/ Serial: CM800662
 Unit Make/ Model: CATERPILLAR. XQ570
 Unit Spec/ Serial: CATXQ570CME500420

Voltage: 277/480
 Amperage: 601
 Kilowatts: 455
 Power Factor: 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	4438.4	4438.6	4438.8	4439.1	4439.4	4439.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	481	481	481	480	481	481
PH1-PH3	481	480	480	481	480	480
PH2-PH3	480	481	481	481	480	481
Amperage PH1	545	545	545	545	545	0
PH2	545	546	546	546	546	0
PH3	546	545	545	545	545	0
KILOWATTS	453	453	453	453	453	0
Oil Pressure	68	66	65	63	63	71
Oil Temperature						
Coolant Temperature	189°F	192°F	192°F	192°F	194°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.4	27.4	27.4	27.4	27.4	27.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	85°F	85°F	85°F	88°F	85°F	85°F

Technician Signature:

Juan Cardenas

Customer Signature:
