

STOWERS POWER SYSTEMS

LOAD BANK REPORT

KNOXVILLE

ENGINE MAKE

GENERATOR MAKE

Customer Name

MODEL

MODEL

SERIAL #

SERIAL #

Customer Equip #

Standby

Prime

HRS Before

HRS After

KW

VOLTS

Rated Amps @ .8

WO #

Test Hours	^T Rad	Water Temp	Exh Temp	Fuel PSI	Oil Press	RPMs	Hz	VOLTS L-L			Volts	VOLTS L-N			PF	AMPS			Amps	KW	Load %
								AB	BC	CA		A	B	C		A	B	C			
WarmUp	46	154	306	99	67	1800	60	480	480	480	480	277	277	277	1	0	0	0	0	0	0.0%
	83																				
BeginTest	73	178	663	96	60	1800	60	480	480	480	480	277	277	277	1	217	217	217	217	180	53.1%
	142																				
15 Min	171	201	889	96	50	1800	60	480	480	480	480	277	277	277	1	426	426	426	426	354	104.2%
	187																				
30 Min	163	199	874	96	50	1800	60	480	480	480	480	277	277	277	1	426	426	426	426	354	104.2%
	180																				
45 Min	164	199	871	96	49	1800	60	480	480	480	480	277	277	277	1	426	426	426	426	354	104.2%
	181																				
60 Min	173	198	860	96	49	1800	60	480	480	480	480	277	277	277	1	426	426	426	426	354	104.2%
	181																				
CoolDown	162	187	502	98	53	1800	60	480	480	480	480	277	277	277	1	0	0	0	0	0	0.0%
	173																				
00:00	124	176	338	99	58	1800	60	480	480	480	480	277	277	277	1	0	0	0	0	0	0.0%
	152																				

REMARKS

Tested by: Mike Mase

Title: GENERATOR TECH

DATE: January 8, 2025