



LOAD BANK TEST REPORT

CUSTOMER: Midwest Engines & Generators Asset ID: E940542943 Site: MEG HQ

Pre-Start up Checks:

<input checked="" type="checkbox"/>	1. Eng. Oil Level	<input checked="" type="checkbox"/>	4. Safety ground connected
<input checked="" type="checkbox"/>	2. Coolant Level	<input checked="" type="checkbox"/>	5. Circuit breaker open (off)
<input checked="" type="checkbox"/>	3. Generator and load bank connected for proper volts		

Test Date: 02/12/25
 Tested By: Michael Cox
 Title: TECHNICIAN
 Tested At: 100%
 Ambient Temp: 31 Deg F

Engine Mfg: Cummins Package Serial Number: E940542943 KW: 600
 Engine Model: VTA-28
 Engine Serial Number: 25195588 Control Panel Model: Analog

RPM: 1800 Hours Before: 1108 Hours After: 1109

Test Load/Duration: 1 HR 15 MIN Min. Record Intervals

TIME	VOLTS			AMPS			FREQ HZ	Boost PSI	LOAD KW	COOL TEMP °F	Lube Oil	FUEL PRESS	% OF LOAD	Battery Voltage
	1	2	3	1	2	3								
12:30PM	480	480	480	192	212	143	60.0	N/A	157	160	75	35	26%	27 VDC
12:45 PM	480	480	480	400	376	331	60.0	N/A	333	160	76	70	55%	27 VDC
1:00 PM	480	480	480	573	572	575	60.0	N/A	478	160	73	110	80%	27 VDC
1:15PM	480	480	480	757	756	758	60.0	N/A	630	166	72	162	105%	27 VDC
Cooldown	480	480	480	0	0	0	60.0	N/A	0	162	75	10	0%	27 VDC
									0				0%	
									0				0%	
									0				0%	
									0				0%	

Customer Acceptance:

By: _____
 Title: _____

By: Michael Cox
 Title: Technician