



Load Bank Test Report

Engine Make/ Model: QSK60-G6
Engine Spec/ Serial: 33164345
Unit Make/ Model: DQKC-5748258
Unit Spec/ Serial: F060931968

Voltage: 480
Amperage: 2408
Kilowatts: 2000
Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	973	973	973	974	974	974	974
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	483	482	482	483	482	483	483
PH2	482	483	483	483	483	482	482
PH3	483	482	482	482	482	483	483
Amperage PH1	0	2317	2316	2317	2316	2316	0
PH2	0	2220	2221	2220	2220	2221	0
PH3	0	2187	2186	2186	2187	2187	0
Kilowatts	0	1864	1864	1864	1863	1865	0
Oil Pressure	86	74	70	69	69	69	71
Coolant Temperature	76	129°F	155°F	156°F	157°F	156°F	138°F
DC Voltage	27.6	27.7	27.6	27.6	27.6	27.7	27.7
Ambient Temperature	47	47°F	47°F	47°F	47°F	47°F	47°F

Technician Signature Jonathan Mueller

Test Date 2/26/2024



2/26/2024

CSDG #4415

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Acceptable
- Yes No NA Check condition of coolant hoses: Acceptable
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: 0
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: QTY 2x, 4990W, single phase 240/480 input
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS:
- Yes No NA Inspect exhaust system for cracks / leaks: Good
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Mechanical Engine: