



Customer: Central States Diesel Generators STK# 4502
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 17496
 Test Date 9-27-24

Engine Make/ Model: CUMMINS KTA-50-G3
 Engine Spec/ Serial: 33116842
 Unit Make/ Model: CUMMINS KTA-50-G3
 Unit Spec/ Serial: D900315041

Voltage: 277/480
 Amperage: 1503
 Kilowatts: 1250*
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1034.5	1034.8	1035	1035.3	1035.5	1035.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	480	480	480	480	480	480
PH1-PH3	481	480	480	481	481	481
PH2-PH3	480	480	480	480	481	480
Amperage PH1	1388	1395	1388	1389	1386	0
PH2	1378	1390	1385	1383	1384	0
PH3	1386	1387	1389	1386	1385	0
KILOWATTS	*1155	*1160	*1156	*1157	*1155	0
Oil Pressure	78	77	75	75	75	77
Oil Temperature						
Coolant Temperature	181°F	180°F	180°F	181°F	181°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	72°F	72°F	72°F	71°F	71°F	71°F

Technician Signature: Randy Pool

Customer Signature: _____



9/27/2024

CSDG # 4502

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-35F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: NONE PRESENT
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: Qty. (2) 240VAC 4000W
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: NOT LABELED
- Yes No NA Inspect exhaust system for cracks / leaks: OPEN SKID UNIT
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Mechanical Engine: