



Customer: Central States Diesel Generators STK# 4508
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 17050
 Test Date 6-3-24

Engine Make/ Model: INTERNATIONAL GCD325
 Engine Spec/ Serial: 1833330C1
 Unit Make/ Model: KOHLER 200DSE
 Unit Spec/ Serial: Spec. PA-192927 S/N 0656514

Voltage: 277/480
 Amperage: 241
 Kilowatts: 200
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	690.2	690.4	690.7	690.9	691.2	691.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	484	484	483	484	483	484
PH1-PH3	483	483	483	484	484	483
PH2-PH3	484	484	484	483	483	484
Amperage PH1	241	242	242	241	241	0
PH2	241	241	242	242	241	0
PH3	242	242	241	241	242	0
KILOWATTS	202	203	202	202	202	0
Oil Pressure	54	52	51	51	51	54
Oil Temperature						
Coolant Temperature	165°F	165°F	165°F	166°F	165°F	165°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	69°F	69°F	70°F	70°F	70°F	71°F

Technician Signature: Randall Pool

Customer Signature: _____



6/3/2024

CSDG # 4508

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-30F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (2) 1231PMF
- Yes No NA Battery install date if applicable: 4/21
- Yes No NA Genset has battery charger: B-325335 120/240VAC, 5.1/3.0A
- Yes No NA Genset has coolant heater: 240VAC 2000W
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: Not Labeled
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: