



Customer: Central States Diesel Generators STK#2468
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 7127
 Test Date 4-24-2019

Engine Make/ Model: Caterpillar 3516
 Engine Spec/ Serial: 25Z03734
 Unit Make/ Model: Caterpillar 3516
 Unit Spec/ Serial: 25Z03734

Voltage: 277/480
 Amperage: 1804
 Kilowatts: 1500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	9343	9343	9343	9343	9344	9344
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	488	487	488	489	488	488
PH2	488	487	488	489	488	488
PH3	489	489	490	489	489	489
Amperage PH1	0	1778	1777	1775	1779	0
PH2	0	1776	1776	1772	1780	0
PH3	0	1779	1777	1774	1768	0
Kilowatts	0	1500	1500	1500	1500	0
Oil Pressure	72	69	68	66	64	69
Oil Temperature						
Coolant Temperature	185°F	188°F	188°F	188°F	188°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26	26	26	26	26	26
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	52°F	52°F	52°F	52°F	53°F	53°F

Technician Signature: Randy Pool

Customer Signature: _____