



Customer: Central States Diesel Generators STK# 4536
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 17239
 Test Date 8-12-24

Engine Make/ Model: JOHN DEERE 6135HF485
 Engine Spec/ Serial: RG6135L027600
 Unit Make/ Model: KOHLER 400REOZJ
 Unit Spec/ Serial: Spec. GM76156-GA2 S/N SGM324G2V

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	380.7	380.9	381.2	381.4	381.7	381.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	479	478	478	478	479	479
PH1-PH3	479	480	480	479	479	479
PH2-PH3	480	480	479	479	480	479
Amperage PH1	481	482	482	480	481	0
PH2	482	481	481	482	481	0
PH3	480	481	481	481	481	0
KILOWATTS	400	400	400	400	400	0
Oil Pressure	48	46	45	45	45	46
Oil Temperature						
Coolant Temperature	177°F	178°F	178°F	177°F	178°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	79°F	79°F	79°F	78°F	78°F	78°F

Technician Signature: Randy Pool

Customer Signature: _____



8/12/2024

CSDG # 4536

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-35F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (2) CAT 115-2422
- Yes No NA Battery install date if applicable: 8/23
- Yes No NA Genset has battery charger: KOHLER, 24VDC/10A
- Yes No NA Genset has coolant heater: E20474, 120V 2500W
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 8/23, 368Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: