



Customer: Central States Diesel Generators STK# 4541
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 17349
 Test Date 8-12-24

Engine Make/ Model: CUMMINS QSM11-G4 NR3
 Engine Spec/ Serial: 35280334
 Unit Make/ Model: CUMMINS DQHAB-6515690
 Unit Spec/ Serial: Spec. D S/N B110191779

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	439.7	439.9	440.2	440.5	440.7	440.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	482	482	482	481	481	482
PH1-PH3	479	480	480	479	479	479
PH2-PH3	478	478	479	479	478	478
Amperage PH1	361	360	361	361	360	0
PH2	360	361	361	360	361	0
PH3	360	360	360	359	361	0
KILOWATTS	300	300	300	300	300	0
Oil Pressure	37	35	34	34	34	35
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	71°F	72°F	72°F

Technician Signature: Randy Pool

Customer Signature: _____



8/12/2024

CSDG # 4541

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-35F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: None
- Yes No NA Battery install date if applicable: 8/17
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: E204747, 240/480V, 4990W 1PH
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 8-12-24 440.8Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks: OPEN SKID UNIT
- Yes No NA Check rain cap for proper operation: OPEN SKID UNIT
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: