



Customer: Central States Diesel Generators STK# 4548
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: Dale Notif.
 Test Date 8-23-24

Engine Make/ Model: CUMMINS QSB7-G3 NR3
 Engine Spec/ Serial: 46977702
 Unit Make/ Model: CUMMINS DSGAC-7570805
 Unit Spec/ Serial: Spec. B S/N A090229612

Voltage: 277/480
 Amperage: 181
 Kilowatts: 150
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	469	469.3	469.5	469.8	470	470.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	480	480	480	480	480	480
PH1-PH3	480	481	481	480	480	480
PH2-PH3	480	480	479	479	480	480
Amperage PH1	180	180	180	179	179	0
PH2	181	180	180	181	180	0
PH3	180	181	180	180	181	0
KILOWATTS	150	150	150	150	150	0
Oil Pressure	52	51	50	50	50	52
Oil Temperature						
Coolant Temperature	185°F	185°F	186°F	186°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.13	14.13	14.13	14.13	14.13	14.13
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	71°F	71°F	71°F

Technician Signature: Randy Pool

Customer Signature: _____



8/23/2024

CSDG # 4548

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-35F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (1) CUMMINS CMF4D, (GOOD)
- Yes No NA Battery install date if applicable: 5/22
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 120VAC/1500W Tank Type
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 8/26/24, 470.1 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: