



Customer: Central States Diesel Generators STK# 4557
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 17358
 Test Date 8-13-24

Engine Make/ Model: CUMMINS NTA-855-G3
 Engine Spec/ Serial: 30364025
 Unit Make/ Model: CUMMINS DFCC-3387637
 Unit Spec/ Serial: Spec. T S/N A000055123

Voltage: 120/208
 Amperage: 972
 Kilowatts: 350
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	304.4	304.6	304.9	305.1	305.4	305.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	210	210	211	210	210	210
PH1-PH3	209	209	209	209	210	209
PH2-PH3	209	210	210	209	210	209
Amperage PH1	971	971	970	970	971	0
PH2	972	972	971	971	971	0
PH3	970	970	971	971	971	0
KILOWATTS	350	350	350	350	350	0
Oil Pressure	45	44	44	44	44	46
Oil Temperature						
Coolant Temperature	196°F	197°F	197°F	196°F	196°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	81°F	80°F

Technician Signature: Randy Pool

Customer Signature: _____



8/13/2024

CSDG # 4557

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-35F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (2) 4D-7/970CCA/295RC
- Yes No NA Battery install date if applicable: 1/14/22
- Yes No NA Genset has battery charger: SENS, EnerGenius
- Yes No NA Genset has coolant heater: 240/480V 4990W
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 4-26-22/304 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Mechanical Engine: