

GENERAC



Customer: csdg
Address: _____
City/ State/ Zip Waukesha Wisconsin
Contact: _____
Phone: _____

R#: 18193
Test Date 1/30/2025

Engine Make/ Model: cummins 6bt5.9g6
Engine Spec/ Serial: 46252041
Unit Make/ Model: cummins onan 100dgd.3324
Unit Spec/ Serial: 1020415531 p

Voltage: 208
Amperage: 277
Kilowatts: 100
Power Factor 1

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 265.1 | | | | 266.1 | 266.1 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 208 | 208 | 208 | 208 | 208 | 208 |
| PH2 | 208 | 208 | 208 | 208 | 208 | 208 |
| PH3 | 208 | 208 | 208 | 208 | 208 | 208 |
| Amperage PH1 | 200 | 277 | 277 | 277 | 277 | 0 |
| PH2 | 200 | 277 | 277 | 277 | 277 | 0 |
| PH3 | 200 | 277 | 277 | 277 | 277 | 0 |
| Kilowatts | 72 | 100 | 100 | 100 | 100 | 0 |
| Oil Pressure | 55 | 50 | 50 | 50 | 50 | 50 |
| Oil Temperature | na | | | | | |
| Coolant Temperature | 175°F | 185°F | 185°F | 185°F | 185°F | 182°F |
| Man Vac./Press. L/B | na | | | | | |
| Man Vac./Press. R/B | na | | | | | |
| L/B Exhaust Temp | na | | | | | |
| R/B Exhaust Temp | na | | | | | |
| Exhaust Temperature | na | | | | | |
| DC Voltage | 14 | 14 | 14 | 14 | 14 | 14 |
| Natural Gas Pressure | na | | | | | |
| Diesel Fuel Level | 0 | | | | | |
| Room Temperature | na | | | | | |
| Ambient Temperature | 39°F | 39°F | 39°F | 39°F | 39°F | 39°F |

Cable Length: _____

Cable/ Leg: _____

Connection Point: generator breaker

Technician Signature: matt

Customer Signature: _____



DATE: 1/30/2025

CSDG # 4568

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -45 dgrees
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: No battery
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level: Full
- Yes No NA Engine oil filters last changed date and HRS: 4-14-23 (249.4 hrs)
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: But has electronic governor