



Customer: Central States Diesel Generators STK# 4585
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 17729
 Test Date 10-7-24

Engine Make/ Model: DETROIT DIESEL Series 60 14L
 Engine Spec/ Serial: 06R0979055
 Unit Make/ Model: KOHLER 300REOZDD
 Unit Spec/ Serial: 2171549

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	439.3	439.5	439.8	440	440.3	440.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	481	480	481	481	480	480
PH1-PH3	480	480	480	480	480	480
PH2-PH3	480	481	481	481	480	480
Amperage PH1	361	360	360	361	361	0
PH2	360	360	361	361	360	0
PH3	361	361	360	360	360	0
KILOWATTS	300	300	300	300	300	0
Oil Pressure	48	47	47	47	46	49
Oil Temperature						
Coolant Temperature	188°F	188°F	188°F	188°F	188°F	181°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	55°F	56°F	56°F	56°F	57°F	57°F

Technician Signature: Randy Pool

Customer Signature: _____



10/7/2024

CSDG # 4585

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-35F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (2) KOHLER GM106699-S (24VDC)
- Yes No NA Battery install date if applicable: 10/21
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: (1) 120VAC 2000W
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 426.8 HRS.
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation: Tested W/O Muffler
- Yes No NA Generator end is 12 lead reconnectable
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: