



Customer: Central States Diesel Generators STK# 4610
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#:
 Test Date 10-29-24

Engine Make/ Model: IVECO F3AE9685A
 Engine Spec/ Serial: E003208467
 Unit Make/ Model: GENERAC SD275
 Unit Spec/ Serial: 3004465021

Voltage: 277/480
 Amperage: 331
 Kilowatts: 275
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	135.9	136.1	136.4	136.6	136.9	137
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	482	482	483	483	482	482
PH1-PH3	479	480	4800	479	479	479
PH2-PH3	484	484	483	483	483	484
Amperage PH1	331	332	332	331	331	0
PH2	335	334	334	335	334	0
PH3	330	330	331	331	330	0
KILOWATTS	276	276	275	276	275	0
Oil Pressure	86	84	84	84	84	85
Oil Temperature	191°F	191°F	192°F	192°F	192°F	180°F
Coolant Temperature	177°F	177°F	176°F	176°F	176°F	171°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.5	28.5	28.5	28.5	28.5	28.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	74°F	74°F	74°F	74°F

Technician Signature: Randy Pool

Customer Signature: _____



10/29/2024

CSDG # 4610

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: (-30F)
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: Qty. (2) CUMMINS C8DXH (0 VDC)
- Yes No NA Battery install date if applicable: 10/23
- Yes No NA Genset has battery charger: GENERAC 24V/10A
- Yes No NA Genset has coolant heater: 208VAC/2500W
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 10/30/24, 91HRS.
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: