

GENERAC



Customer: csdg
Address: _____
City/ State/ Zip Waukesha Wisconsin
Contact: _____
Phone: _____

R#: 18190
Test Date 1/29/2025

Engine Make/ Model: cummins qsl9g2nr3
Engine Spec/ Serial: 21799841
Unit Make/ Model: cummins onan dshaa.5936858
Unit Spec/ Serial: j070117779

Voltage: 480
Amperage: _____
Kilowatts: 150
Power Factor: _____

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2894.4				2895.4	2895.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	485	485	485	485	485
PH2	484	484	484	484	484	484
PH3	485	485	485	485	485	484
Amperage PH1	180	180	180	180	180	0
PH2	180	180	180	180	180	0
PH3	180	180	180	180	180	0
Kilowatts	151	151	151	151	151	0
Oil Pressure	54	54	54	54	54	54
Oil Temperature	na					
Coolant Temperature	187°F	187°F	187°F	187°F	187°F	187°F
Man Vac./Press. L/B	na					
Man Vac./Press. R/B	na					
L/B Exhaust Temp	na					
R/B Exhaust Temp	na					
Exhaust Temperature	na					
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure	na					
Diesel Fuel Level	0					
Room Temperature	na					
Ambient Temperature	39°F	39°F	39°F	39°F	39°F	39°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: gen breaker

Technician Signature: matt

Customer Signature: _____



DATE: 1/29/2025

CSDG # 4633

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -45 degrees
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (2) Group 24 top post (cores)
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level: Full
- Yes No NA Engine oil filters last changed date and HRS:
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine:
- Yes No NA Mechanical Engine: But has electronic governor